

Typical Specification:

Provide, where indicated, a flexible connector consisting of 300 series stainless steel corrugated hose surrounded and supported by 300 series stainless steel braid. End fittings are to be carbon steel Schedule 40 pipe nipples. Connector to be _____ inches nominal pipe size by _____ Inches overall length; **Thermo Tech model FFNS or equal**.

NOMINAL PIPE SIZE INCHES	OVERALL LENGTH INCHES	HOSE & BRAID WORKING PRESSURE PSIG
1/2"	6 1/2"	995
3/4"	7"	750
1"	8"	605
1 1/4"	8 1/2"	570
1 1/2"	9"	525
2"	10 1/2"	455
Job		
Contractor Engineer		
-		
Representative Order No Date		
	Dat	6
Submitted by		
Approved by	Date	
Tag		

Notes:

Special end fittings, lengths, and pressure ratings are available.

Maximum working pressure is based on non-shock service at 70°F.

Braided metal connectors are not designed for compression or extension.

Install the connectors without torque, sharp bends, or any excessive offset.



287 South Sante Fe Drive Denver, Colorado 80223 Phone (303) 698-9988 www.thermotechdenver.com

Flexible Connector Type FFNS